ACME WATER DISTRICT

2025 Water Quality Report

Annual consumer confidence report · Published 2026

Your Water Meets Standards

Acme Water District's drinking water met all state and federal standards in 2025. This report explains where your water comes from, how it's treated, and what we test for.

Where Your Water Comes From

Our water comes from groundwater wells and treated surface water, blended and disinfected before it reaches your tap.

Test Results

Contaminant	Result	Limit
Total coliform bacteria	None detected	Presence in 5% of samples
Lead (90th percentile)	3 parts per billion	Action level: 15 ppb
Copper (90th percentile)	0.4 parts per million	Action level: 1.3 ppm
Nitrate	2.1 parts per million	Limit: 10 ppm
Chlorine residual	1.1 parts per million	Limit: 4 ppm

Results are samples for demonstration only.

Contact

Acme Water District Customer Service · (800) 222-7777 · customerservice@acmewater.example.org · Monday to Friday, 8:00 AM to 5:00 PM · 24-hour water emergencies: (800) 222-7777